

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012



JAVIER NUNEZ  
PRESIDENT

ELVIN W. MOON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
LAUREL GILLETTE  
GEORGE HOVAGUIMIAN

ERIC GARCETTI  
MAYOR

OSAMA YOUNAN, P.E.  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

JOHN WEIGHT  
EXECUTIVE OFFICER

Kevin L. Birchmeier  
TOPP Industries, Inc.  
Hwy 25 North, P.O. Box 420  
Rochester, IN 46975

RESEARCH REPORT: RR 5743  
EFFECTIVEDATE: 10/01/2022  
EXPIRATIONDATE: 10/01/2023  
Telephone: 574-223-3681

**GENERAL APPROVAL - Renewal** – Polyethylene and Structural Foam Sump Basins manufactured by TOPP Industries, Inc. See attached list of approved models.

## DETAILS

These products are plastic sump basins constructed of structural foam and polyethylene. All polyethylene and structural foam models, except “The Cube”, are round basins available in various diameters and depths. “The Cube” model is of hexagonal shape and is available in 6-gallon capacity only. Cast iron and composite fiberglass caulking hubs, PVC grommets as well as stainless steel or enamel coated pipe couplings are available as side inlets. Covers made of structural foam or metal are made for single or twin pump mountings, and a vent connection. Covers are secured by a flange and bolts. 3M Windo-Weld Ribbon Sealer applied between the cover and the basin provides a water-tight joint and enables the sump basin assembly to meet the 10-foot head pressure test per Section 94.712.2 of Los Angeles Plumbing Code (LAPC), 2020 Edition.

The approval is subject to the following conditions.

1. These sumps may be installed only in plumbing drainage systems, such as DWV, rainwater and subsurface drainage.
2. These sumps shall be adequately restrained where the ground water level may cause flotation.
3. Pumps may rest on the bottom of the basin provided the basin sits on a minimum 4-inch compacted sub-base.
4. Access, as required by the Los Angeles Electrical Code, shall be provided for maintenance and repair of any electrical equipment.

RR-5743  
Page 1 of 4

TOPP Industries, Inc.

RE: Sump Basins

5. Where any portion of the sump is located within 10 feet of a property line, bearing wall, or the toe of a slope which exceeds four feet in vertical height, the location and size of each installation shall be indicated on plans approved by the Building Plan Check Section of the Permit and Engineering Bureau.
6. When located within a building, the sump shall be buried in the ground or encased in a minimum of 4 inches of concrete.
7. Only the 3M Windo-Weld Ribbon Sealer shall be used between the cover and the basin.
8. Each sump shall be marked with a permanent label attached to the sump showing the manufacturer's name, "TOPP Industries, Inc." and the appropriate model number where visible for inspection purposes.

## **DISCUSSION**

The Mechanical Testing Laboratory reviewed recent test reports. These products have been tested in accordance with IAPMO PS 52. The material and construction are equivalent to that prescribed by the Los Angeles Municipal Code in quality, strength, effectiveness, durability and safety.

For this General Approval to be valid on any individual construction project in the City of Los Angeles, an engineer or inspector of the Department of Building and Safety must make a determination that all conditions of the General Approval required to provide equivalency have been met in the case of each construction project under consideration.

This approval is granted under Sections 94.301.0, 94.710.7, 94.710.8, 94.710.9, 94.710.10, and 94.712.2 of the Los Angeles Plumbing Code, 2020 Edition and Section 91.2612.0 of the Los Angeles Building Code, 2020 Edition.

Approved by:

Irene Pool  
Mechanical Testing Laboratory  
Permit and Engineering Bureau

**TOPP INDUSTRIES, INC.**  
**RR-5743**

**LIST OF APPROVED STRUCTURAL FOAM MODELS:**

<u>Model #</u>	<u>Description</u>
E1-B1100	E-Series Structural Foam (The Cube)
E11-1100-##	13" X 13" E-Series Structural Foam Basin
E2-2200-##	18" X 22" E-Series Structural Foam Basin
E3-2400	18" X 30" E-Series Structural Foam Basin
E4-3100	24" X 24" E-Series Structural Foam Basin
E5-3200	24" X 36" E-Series Structural Foam Basin
E6-4100	30" X 36" E-Series Structural Foam Basin
E7-1824	18" X 24" E-Series Structural Foam Basin

**LIST OF APPROVED POLYETHYLENE MODELS:**

<u>Model #</u>	<u>Description</u>
B1100-##	13" X 13" Polyethylene Basin
B1104-##	14" X 24" Polyethylene Basin
B2200#-##	18" X 22" Polyethylene Basin
B1800#-##	18" X 24" Polyethylene Basin
SHDB240-##	18" X 24" HD Polyethylene Basin
B2400#-##	18" X 30" Polyethylene Basin
SHDB242-##	18" X 30" HD Polyethylene Basin
B2700#-##	23" X 31" Polyethylene Basin
B3100#-##	24" X 24" Polyethylene Basin
B3200#-##	24" X 36" Polyethylene Basin
B3300#-##	24" X 30" Polyethylene Basin
B4100#-##	30" X 36" Polyethylene Basin
B5100#-##	36" X 36" Polyethylene Basin

<u>Covers:</u>	<u>Description</u>
E-C**EWSF-####	Solid Structural Foam Cover
E-C**EWSFE-####	Single Hole Structural Foam Cover
E-C**G-####	Simplex Structural Foam Cover with Gaskets
E-C**F-####	Simplex Structural Foam Cover with Flanges
E-C**TSF-####	Simplex Two- Piece Structural Foam Cover
C**WSL-####	Light Duty Solid Steel Cover
C**WSH-####	Heavy Duty Solid Steel Cover
C**WP-####	Solid Polyethylene Cover

TOPP Industries, Inc.  
RE: Sump Basins

C**SP-####	Simplex Polyethylene Cover
C**SSL-####	Light Duty Simplex Steel Cover
C**SSH-####	Heavy Duty Simplex Steel Cover
C**WFNSTP-####	Solid Fiberglass Cover
C**FSNSTP-####	Simplex Fiberglass Cover
C**SFA-####	Simplex Fiberglass with Access Cover
C**DFA-####	Duplex Fiberglass with Access Cover
C**SSA-####	Simplex Steel with Access Cover
C**-12SSA-####	Simplex Steel with Access Cover (12g)
C**DSA-####	Duplex Steel with Access Cover
C**-12DSA-####	Duplex Steel with Access Cover (12g)
C**HSS-####	Steel Hatch Cover
C**HSA-####	Aluminum Hatch Cover

LEGEND:

##(##)= Model options  
\*\*=Cover diameter