


IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING



IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued To:

TOPP INDUSTRIES INC.

P.O. BOX 420 - HWY 25N, ROCHESTER, IN 46975, UNITED STATES

Product:

Prefabricated Gravity Grease Interceptors

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)
National Plumbing Code of Canada

Products are certified to the following standard(s)

ANSI/CAN/IAPMO Z1001-2021

File Number: 17429

Revised Date: June 5, 2026

Effective Date: May 2025

Void After: May 2030*


Chairman, Product Certification Committee





Chief Technical Service Officer

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: TOPP INDUSTRIES INC.

File Number: 17429

Product: Prefabricated Gravity Grease Interceptors

Effective Date: May 2025

Revised Date: June 2026

Void After: May 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Prefabricated gravity grease interceptors shall be permanently and legibly marked with the manufacturer's name and/or trademark, model number, working liquid volume (expressed at least in gallons), date (i.e. month and year), date code, or identifier traceable to the date of manufacture, maximum design load, maximum burial depth, inlet, and outlet. The markings shall be applied on permanently-affixed metal plates, etched, mechanically stamped, stamped with permanent (non-water-soluble) ink, or molded. Adhesive labels that comply with UL 969 shall also be considered permanent when placed on a surface that is not normally submerged in water. The product shall also bear the cUPC® certification mark.

Characteristics:

Prefabricated gravity grease interceptors made of concrete, fiber reinforced polyester (FRP), thermoplastic, or steel. Grease interceptors with at least two (2) compartments designed to remove grease from effluent and to retain grease until accumulations can be removed by pumping the interceptor.

Grease interceptors shall have a minimum size of 20 inches of manhole over the inlet and outlet compartments. It is recommended that a sample box be located at the outlet end of all grease interceptors so that the administrative authorities can periodically sample effluent quality.

To be installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code and the National Plumbing Code of Canada.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Models

Model Number	Description
INTERCEPTOR 500	500gal
INTERCEPTOR 750	750gal
INTERCEPTOR 1000	1000gal
INTERCEPTOR 1600	1600gal